



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Jolimont Rd 102-104, East Melbourne  
102-104 Jolimont Rd East Melbourne  
Contract No: P3233

## Callouts:

Date of Call: 15-12-2018 8:00:00  
Time of Arrival: 15-12-2018 8:00:00  
Rectification Time: 15-12-2018 11:00:00  
Time of Departure: 15-12-2018 11:00:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Chargeable Callout

**For Lift(s):**

**For Floor(s):** \*

**Call Description:** Provide access for plumbers to pump floodwater out of pit.

**Order Number:** \*

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift pit flooded, provided access for plumbers to pump water out of pit. Replaced pit emergency stop switch. Returned to service. Tested ok.

**Part Required:** Emergency stop switch

**Service Technician**

Nathan Downton

**Report Customer**

\*