



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

City Gate Hotel/Doubletree  
270 Flinders St Melbourne  
Contract No: P3103

**Callouts: 22740**

Date of Call: 31-12-2018 13:43:24  
Time of Arrival: 31-12-2018 14:00:00  
Rectification Time: 31-12-2018 14:20:00  
Time of Departure: 31-12-2018 14:25:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Noisy

**For Lift(s):** 1

**For Floor(s):** ?

**Call Description:** service lift is making a ticking noise when door closes - on all levels

**Order Number:** x

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** Lubricate

**Work Description:** Lubricated belt pulley on car doors.

**Part Required:** No Parts Required

**Service Technician**

Gavin Pedlar

**Report Customer**

Sawad 9654 6888