



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Bowen Cres 3, Melbourne
3 Bowen Cres Melbourne
Contract No: P3031

Callouts: 22447

Date of Call: 30-11-2018 14:49:33
Time of Arrival: 30-11-2018 15:15:00
Rectification Time: 30-11-2018 15:35:00
Time of Departure: 30-11-2018 15:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): 6

Call Description: down button in the lobby is not working, on level 6

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Button Broken

Work Action (CORRECTION): Replace/Repair Button

Work Description: Found level 6 landing down button with the rear of the body broken, all 4 screws pushed out of the housing and board dislodged from case. Replace button and test operation - ok

Part Required: 1 x hunter down landing button.

Service Technician

Kevin Wilkins

Report Customer

.