



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Riggall St 61**

61 Riggall Street Broadmeadows

Contract No: P3608

## Callouts ID: 21956

Date of Call: 18-10-2018 10:43:00

Time of Arrival: 18-10-2018 9:44:00

Rectification Time: 18-10-2018 10:44:00

Time of Departure: 18-10-2018 11:44:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** 5

**Call Description:** small lift is stuck on 5th floor

**Order Number:** #

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift over to top on level 5, RA contact high resistant. Cleaned finger contacts and returned to service. Checked all other possible causes.

**Part Required:** No Parts Required

**Service Technician**

Marek Torrico

**Report Customer**

Ken Allen 0448 521 112