



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Potter Street 12-16, Dandenong
12-16 Potter Street Dandenong
Contract No: P3646

Callouts: 22487

Date of Call: 05-12-2018 13:25:11
Time of Arrival: 05-12-2018 14:15:00
Rectification Time: 06-12-2018 10:45:00
Time of Departure: 05-12-2018 14:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): B

Call Description: lift is out of order

Order Number: 15909

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found lift on B with water ingress from level G basement lock wet, car door operator wet, light Ray wet. RCD CP2 tripping, unable to return service until dry. People from home concrete solutions onsite hosing ground level floors around the lift shaft.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

Elle 1800 066 088