



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Pegasus Suites Hotel
206-216 A'Beckett St Melbourne
Contract No: P3382

Callouts ID:

Date of Call: 20-10-2018 20:07:00
Time of Arrival: 20-10-2018 20:55:00
Rectification Time: 20-10-2018 21:40:00
Time of Departure: 20-10-2018 21:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 4

For Floor(s): 12

Call Description: Lift ooo level 12 with doors open not level

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 4 shutdown due to not consistently stopping level, encoder count issue

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

reception