



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Queen St 39, Melbourne  
39 Queen St Melbourne  
Contract No: P3542

## Callouts ID: 22092

Date of Call: 24-10-2018 15:22:16  
Time of Arrival: 24-10-2018 15:50:00  
Rectification Time: 24-10-2018 18:20:00  
Time of Departure: 24-10-2018 18:30:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1,2

**For Floor(s):** 1

**Call Description:** water leakage coming from lifts. Both lifts are on shut down

**Order Number:** .

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift 1 and 2 pits flooded \r\nwater leaking from level 7 sprinkler\r\nchecked lift cars for trapped passengers \r\nnear tops and landing door lock wet,\r\nsafety circuit open.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

Jay 0478 087 440