



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Strathmerton Steet 16
16 Strathmerton Street Reservoir
Contract No: 3658

Callouts:

Date of Call: 19-11-2018 23:25:00
Time of Arrival: 20-11-2018 0:15:00
Rectification Time: 20-11-2018 0:30:00
Time of Departure: 20-11-2018 1:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 2

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Clean Light Ray

Work Description: Lift roa but intermittently getting stuck at floors due to light ray fault\r\nLight ray triggering when no obstruction \r\nCheck and clean light ray and fault cleared\r\nTest ok

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer