



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Guardian Childcare Centre (ONLY)
670 Chapel St South Yarra
Contract No: P3557

Callouts: 22714

Date of Call: 27-12-2018 8:45:00
Time of Arrival: 27-12-2018 9:10:00
Rectification Time: 27-12-2018 9:40:00
Time of Departure: 27-12-2018 9:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): M

Call Description: repair lift not operating at middle lift.

Order Number: 26469-00144

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Replace/Repair Reply or Contactor

Work Description: Found "\"DRM contactor blocking\" fault, inspected contactors, tested for make, reset controller, returned to service, tested ok.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

*