



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
03 9687 9099  
info@unitedlifts.com.au

Customer Details:

1-3 Railway Place  
1-3 Railway Place Cremorne  
Contract No: 3572

## Maintenance:

Date of Call: 01-11-2018  
Time of Arrival: 9:00:00  
Time of Departure: 10:20:00

### Maintenance Details

**Maintenance Description:** Routine maintenance. \r\nReplaced broken handrail in lift 1. Found lift two, right handrail broken, missing handrail nowhere to b found. Referred to supervisor for follow up with building manager.

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check pit equipment and check water for pit	Y	Y
Test Lift Communications	Y	Y

**Service Technician**

Nathan Downton

**Customer Email**

Nathan@allianceocm.com.au