



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glen Eira Sports & Aquatic Centre
200 East Boundary Road BENTLEIGH EAST
Contract No: P3399

Callouts:

Date of Call: 14-12-2018 10:15:00
Time of Arrival: 14-12-2018 10:35:00
Rectification Time: 14-12-2018 10:50:00
Time of Departure: 14-12-2018 10:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: Lift ooo

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift had all circuits but out of order check safties locks and proving citcuits all ok.\r\nPut lift on inspection and then normal and lift ran. Powe
disturbance potential cause.\r\nAlso checked doors for obstructions and operation

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0