



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Faversham House
27 Shierlaw Ave Canterbury
Contract No: P3200

Maintenance:

Date of Call: 13-12-2018
Time of Arrival: 8:00:00
Time of Departure: 10:15:00

Maintenance Details

Maintenance Description: Regular service \r\nAdjust level 2 doors on lift 3

Maintenance Task	1	2	3	4	5
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y	Y	Y
Test all car safties	Y	Y	Y	Y	Y
Clean & Check all M/R Equipment	Y	Y	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y	Y	Y
Check tuning ajustments	Y	Y	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y	Y	Y
Check hydrolic tank oil level, valves RAM etc	Y	Y	Y	Y	Y
Test Emergency Light Unit	Y	Y	Y	Y	Y
Test Lift Communications	Y	Y	Y	Y	Y

Service Technician

Zane Tregurtha

Customer Email

c.machrie@basscare.org.au