



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glen Eira Sports & Aquatic Centre
200 East Boundary Road BENTLEIGH EAST
Contract No: P3399

Callouts: 22601

Date of Call: 14-12-2018 9:31:00
Time of Arrival: 14-12-2018 11:31:00
Rectification Time: 14-12-2018 11:40:00
Time of Departure: 14-12-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): G

Call Description: lift is out of order, showing a dash on the display

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Reset Control System

Work Description: Found lift out of service on level G with no errors showing. Reset controls and test - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

joel 0417507587