



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Bourke St 415, Melbourne
415 Bourke St Melbourne
Contract No: P3143

Callouts: 22559

Date of Call: 11-12-2018 11:20:19
Time of Arrival: 11-12-2018 12:15:00
Rectification Time: 11-12-2018 14:30:00
Time of Departure: 11-12-2018 14:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): basement

Call Description: lift stuck with door open

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Brake fault,\r\nbrake switch contact broken \r\nreplaced contact checked brake function tested ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Prudence (Victoria body corporate) 85318199