



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Knox City Apartments
337 Stud Rd / 400-408 Burwood Road Wantirna South
Contract No: P3244

Callouts ID:

Date of Call: 21-10-2018 17:40:00
Time of Arrival: 21-10-2018 18:30:00
Rectification Time: 21-10-2018 19:06:00
Time of Departure: 21-10-2018 19:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 3

Call Description: Lift ooo on level 3

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift ooo on level 3 with fault 20 \r\nCleaned and adjusted read switches tested lift

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

reception