



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 221, Melbourne
221 Queen St Melbourne
Contract No: P3387

Callouts ID: 22034

Date of Call: 19-10-2018 9:50:18
Time of Arrival: 19-10-2018 10:10:00
Rectification Time: 19-10-2018 15:30:00
Time of Departure: 19-10-2018 16:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): .

Call Description: lift is out of order, keeps breaking down

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Error 71 and 113\nsupplied and fitted new drive contactor MG5 BF checked operation.

Part Required: Drive contactor MG5 BF\n110VAc 37Amp

Service Technician

Robert Pelle

Report Customer

.