



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

ANZAC House
4 Collins St Melbourne
Contract No: P3085

Callouts: 22327

Date of Call: 19-11-2018 9:15:00
Time of Arrival: 19-11-2018 9:40:00
Rectification Time: 19-11-2018 9:55:00
Time of Departure: 19-11-2018 10:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): g

Call Description: out of order

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift overrun bottom floor reset and tested

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

x