



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Barristers Chambers 205 William St  
205 William St Melbourne  
Contract No: P3207

**Callouts: 22507**

Date of Call: 07-12-2018 9:52:49  
Time of Arrival: 07-12-2018 13:20:00  
Rectification Time: 07-12-2018 13:45:00  
Time of Departure: 07-12-2018 13:50:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** basement

**Call Description:** lift 1 is stuck in the basement with the doors closed

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Landing doors in basement not fully closing, cleaned and checked landing door equipment on basement doors checked operation ok.

**Part Required:** No Parts Required

**Service Technician**

Robert Pelle

**Report Customer**

Domenic 0429479834