



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Caroline Street 41
40 Caroline Street South Yarra
Contract No: W3686

Callouts: 22120

Date of Call: 26-10-2018 16:31:37
Time of Arrival: 26-10-2018 17:00:00
Rectification Time: 26-10-2018 17:30:00
Time of Departure: 26-10-2018 17:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 1

For Floor(s): *

Call Description: door limit fault, lift stopping at every level and doors are opening

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Tenant witnessed lift doors open on uncalled floors. Checked fault log, no faults present, reset lift, no issues found. Returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

*