

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Metro Coolaroo
Metro Coolaroo Station Coolaroo
Contract No: P3592

Callouts: 22441

Date of Call: 30-11-2018 10:09:53 Time of Arrival: 30-11-2018 11:00:00 Rectification Time: 30-11-2018 11:40:00 Time of Departure: 30-11-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): top level

Call Description: lift stuck on top level\r\nSite contact: 9619 1109

Order Number: 02AA602508

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Car door fault. Adjust locking mechanism and test operation.

Part Required: No Parts Required

Service Technician Report Customer

mat tehan John from Victrack