

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Franklin St 50, Melbourne
50 Franklin St Melbourne
Contract No: P3301

## Callouts ID:

Date of Call: 24-10-2018 6:40:00 Time of Arrival: 24-10-2018 7:30:00 Rectification Time: 24-10-2018 17:00:00 Time of Departure: 24-10-2018 17:00:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): Chargeable Callout

**For Lift(s):** 1,2,3,4

For Floor(s): ?

Call Description: All lifts out of order.

**Order Number:** x

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift pits flooded.

Part Required: No Parts Required

Service Technician Report Customer

Gavin Pedlar