



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Prahran
27 King St Prahran
Contract No: P3433

Callouts ID: 22090

Date of Call: 24-10-2018 13:53:46
Time of Arrival: 24-10-2018 14:10:00
Rectification Time: 24-10-2018 15:25:00
Time of Departure: 24-10-2018 15:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 6

Call Description: lift is out of order with the doors closed

Order Number: 15294

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift ooo with opnav fault, found brake pick switch high resistance. Changed brake switch and tested

Part Required: Brake pick switch

Service Technician

Dwain Sanderson

Report Customer

.