



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

East Brunswick Hotel
280 Lygon Street East Brunswick
Contract No: B3765

Callouts:

Date of Call: 06-11-2018 14:16:00
Time of Arrival: 06-11-2018 12:16:00
Rectification Time: 06-11-2018 15:50:00
Time of Departure: 06-11-2018 16:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s):

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift shut down water in controller\r\nAll components in controller covered in water including the plcs, relays, contactors etc\r\nBottom of controller filling up with water\r\ncontrollee out side with out adequate cover and water running down wall into back of controller\r\n

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer