



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Eden Apartments
1 Acacia Place Abbotsford
Contract No: P3453

Callouts: 22549

Date of Call: 10-12-2018 15:07:23
Time of Arrival: 10-12-2018 15:30:00
Rectification Time: 10-12-2018 15:50:00
Time of Departure: 15-12-2018 15:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): *

Call Description: left lobby on level 2. Down button is not working

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Button Broken

Work Action (CORRECTION): Replace/Repair Button

Work Description: Button mechanism had separated from housing, replaced and returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

Harris 0448971433/0427003404