



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Queen St 341
341 Queen Street Melbourne
Contract No: P3719

Callouts: 22282

Date of Call: 14-11-2018 11:11:19
Time of Arrival: 14-11-2018 11:30:00
Rectification Time: 14-11-2018 11:50:00
Time of Departure: 14-11-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Closed

For Lift(s): 3

For Floor(s): 10

Call Description: lift is out of order

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Drive Lift Back Through Limit

Work Description: Lift above the top floor. Reset lift and checked controller contactors.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x