



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

ACU

115 Victoria Parade Fitzroy

Contract No: B3045

Callouts: 22466

Date of Call: 03-12-2018 12:08:10

Time of Arrival: 03-12-2018 13:15:00

Rectification Time: 03-12-2018 14:55:00

Time of Departure: 03-12-2018 15:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): Modular Building

For Floor(s): gnd

Call Description: The door closer/arm is missing from the lift of the modular building and as a result, the door can only be closed if someone from the outside pushes it closed.

Order Number: WOT0010148

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Door closer broken \r\nOperating arm missing\r\nReplace closer with new one

Part Required: Door closer

Service Technician

Phil Dodsworth

Report Customer

reception