



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Aurora (582 St Kilda Rd, Melbourne)
582 St Kilda Rd Melbourne
Contract No: P3402

Callouts: 22153

Date of Call: 31-10-2018 14:49:53
Time of Arrival: 31-10-2018 15:15:00
Rectification Time: 31-10-2018 15:40:00
Time of Departure: 31-10-2018 16:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 1

For Floor(s): 9

Call Description: Lift 1 was reported to be stalling on level 9. Person was stuck in lift but was able to get out

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Door lock out of adjustment cleaned and adjusted ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

Warren - 0425 768 822