



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Laminex

130 Sharps Rd Tullamarine

Contract No: P3089

Maintenance:

Date of Call: 19-12-2018
Time of Arrival: 15:20:00
Time of Departure: 16:00:00

Maintenance Details

Maintenance Description: Routine maintenance. Test emergency phone

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning adjustments	Y
Check car door operator and associated equipment.	Y
Check pit equipment and check water for pit	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Lift Communications	Y

Service Technician

mat tehan

Customer Email