



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Melbourne
27 King St Melbourne
Contract No: P3304

Callouts:

Date of Call: 15-12-2018 7:40:00
Time of Arrival: 15-12-2018 7:50:00
Rectification Time: 15-12-2018 8:05:00
Time of Departure: 15-12-2018 8:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 5

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Doors out of mesh\r\nSuspect doors hit to make this occur as door track and rollee penetration all ok\r\nRealign doors and test operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer