

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Lt Collins St 390, Melbourne
390 Lt Collins St Melbourne
Contract No: P3218

Callouts: 22606

Date of Call: 14-12-2018 12:51:22 Time of Arrival: 14-12-2018 13:40:00 Rectification Time: 14-12-2018 14:40:00 Time of Departure: 14-12-2018 14:45:00

## CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): 3

For Floor(s): .

Call Description: lift making noise when running.

Order Number: .

## **DESCRIPTION OF WORK**

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: checked car top equipment \r\nchecked belt drive rollers on car top adjusted checked operation tested ok.

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle Lauren 0418911504