



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

55 South Bank Boulevard
55 South Bank Boulevard South Bank
Contract No: P3612

Maintenance:

Date of Call: 12-11-2018
Time of Arrival: 9:00:00
Time of Departure: 10:10:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning ajustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check and ajust car & cwt guide shoes	Y	Y
Check all safety switches, limits in lift well	Y	Y
Check pit equipment and check water for pit	Y	Y
Clean lift well equipment	Y	Y
Test Lift Communications	Y	Y

Service Technician

Brad Stellini

Customer Email

Don.Beckley@colliers.com