



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton
141 Nicholson St Carlton
Contract No: P3118

Callouts:

Date of Call: 06-12-2018 20:15:00
Time of Arrival: 06-12-2018 22:00:00
Rectification Time: 06-12-2018 22:44:00
Time of Departure: 06-12-2018 23:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 12

Call Description: Lift 1 ooo on level 12

Order Number: 15931

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Llevel 14 landing doors snagging, preventing from closing fully. Adjusted doors, run and tested. Returned to service

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.