



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Melbourne Business College (200 Leicester St, Carlton)
200 Leicester St Carlton
Contract No: P3310

Callouts: 22197

Date of Call: 05-11-2018 12:37:06
Time of Arrival: 05-11-2018 13:35:00
Rectification Time: 05-11-2018 15:39:00
Time of Departure: 05-11-2018 15:39:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): G

Call Description: Replace broken button for lift. It is on the Ground floor at reception on the Sony side.\r\nPlease call Mick when arriving on site

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Button Broken

Work Action (CORRECTION): Replace/Repair Button

Work Description: Lift 1 Ground floor landing button smashed. Picked up replacement button and installed. Replacement button not the same series as original buttons, so will order new button and follow up. Returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

Mick Dillon 0407824005