



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

CSR Gyprok
277 Whitehall St Yarraville
Contract No: P3313

Callouts ID:

Date of Call: 22-10-2018 9:25:00
Time of Arrival: 22-10-2018 9:40:00
Rectification Time: 22-10-2018 10:00:00
Time of Departure: 22-10-2018 10:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s):

For Floor(s): g

Call Description: Lift ooo doors open

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Lift Overloaded

Work Action (CORRECTION): Reset Control System

Work Description: Lift ooo below ground floor \r\nLift had been over loaded again \r\nReset and test operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer