



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Westall
Metro Westall Station Clayton
Contract No: P3588

Callouts ID:

Date of Call: 20-10-2018 18:32:00
Time of Arrival: 20-10-2018 19:16:00
Rectification Time: 20-10-2018 19:58:00
Time of Departure: 20-10-2018 20:05:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): Lift 3

For Floor(s): concorse

Call Description: Lift 000 with doors partially open

Order Number: 02aa599733

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 3 000 with doors unable to close fully, found LHS landing door dragging on ground due to a broken door hanger fixture. Re fixed and tested lift operation

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

stationmaster