

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

Batman's Hill on Collins
623 Collins Street Melbourne
Contract No: P3681

Callouts ID:

Date of Call: 20-10-2018 9:50:00 Time of Arrival: 20-10-2018 10:00:00 Rectification Time: 20-10-2018 10:24:00 Time of Departure: 20-10-2018 10:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 6

For Floor(s): g

Call Description: Lift 6 000

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 6 000 with 83 loss of position fault \r\nCleaned all cigar switches on cartop land checked clearances of magnets in shaft\r\nTested lift

Part Required: No Parts Required

Service Technician Report Customer

Dwain Sanderson reception