



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts:

Date of Call: 13-11-2018 21:54:00
Time of Arrival: 13-11-2018 22:00:00
Rectification Time: 13-11-2018 22:10:00
Time of Departure: 13-11-2018 22:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): g

Call Description: Ooo

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Reset Control System

Work Description: Checked and reset door operator, check cds

Part Required: No Parts Required

Service Technician

Steven Johnson

Report Customer

q