



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Gowanlea Boarding House
1049 Whitehorse Rd Box Hill
Contract No: 3474 - B077

Callouts:

Date of Call: 03-01-2019 19:53:00
Time of Arrival: 03-01-2019 21:40:00
Rectification Time: 03-01-2019 22:25:00
Time of Departure: 03-01-2019 22:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 2

For Floor(s): .

Call Description: reported water dripping from roof into lift 2\r\nalso can smell some burning smell.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Water leaking from aircond unit in lift motor room, water dripping down onto car top and leaking through roof onto the floor in lift car,\r\nturn lift off till further notice.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

ian