



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholson Street 141, Carlton
141 Nicholson St Carlton
Contract No: P3118

Callouts:

Date of Call: 22-12-2018 19:50:00
Time of Arrival: 22-12-2018 20:10:00
Rectification Time: 22-12-2018 21:40:00
Time of Departure: 22-12-2018 22:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 2

For Floor(s): g

Call Description: Doors opening and closing

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Ground floor rhs landing door not closing fully\r\nAircord obstructing door lock from dropping in\r\nAdjust and test

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer