



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

Waltham St 9, Sandringham  
9 Waltham St Sandringham  
Contract No: P3260

**Callouts: 22652**

Date of Call: 18-12-2018 10:00:05  
Time of Arrival: 18-12-2018 10:15:00  
Rectification Time: 18-12-2018 11:30:00  
Time of Departure: 18-12-2018 11:45:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Doors Opening And Closing

**For Lift(s):** 1

**For Floor(s):** G

**Call Description:** lift doors are trying to close but keep opening

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Adjusted open door limit, test - ok.

**Part Required:** No Parts Required

**Service Technician**

Kevin Wilkins

**Report Customer**

vince 03950307787