



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts:

Date of Call: 25-11-2018 9:12:00
Time of Arrival: 25-11-2018 10:50:00
Rectification Time: 25-11-2018 11:20:00
Time of Departure: 25-11-2018 11:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): G

Call Description: Lift out of order with doors open.

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Faulty door zone inductor. Previous water damage on car top.

Part Required: No Parts Required

Service Technician

Gavin Pedlar

Report Customer

x