



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:
Queen St 341
341 Queen Street Melbourne
Contract No: P3719

Callouts ID: 22115

Date of Call: 26-10-2018 11:08:43
Time of Arrival: 26-10-2018 15:08:00
Rectification Time: 26-10-2018 14:28:00
Time of Departure: 26-10-2018 14:48:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 3

For Floor(s): .

Call Description: light globe not working

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Emergency light unit tripped due to low voltage on battery. Reset and ordered new battery

Part Required: No Parts Required

Service Technician

James Wallace

Report Customer

.