

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address: St Kilda Rd 437, Melbourne 437 St Kilda Rd Melbourne Contract No: P3104

Callouts: 22334

Date of Call: 19-11-2018 13:56:28 Time of Arrival: 19-11-2018 14:20:00 Rectification Time: 19-11-2018 14:40:00 Time of Departure: 19-11-2018 15:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Not Stopping Level

For Lift(s): 2

For Floor(s): ground floor

Call Description: lift 2 is not leveling on ground floor, the floor indicator chime on level 6 sounds broken

Order Number: CWO0236666

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Adjusted floor level on ground \r\nGong on level 6 lift 1 to be replaced \r\n

Part Required: New gong

Service Technician Report Customer

Brad Stellini