



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Flinders Ln 125, Melbourne
125 Flinders Lane Melbourne
Contract No: P3254

Callouts: 22493

Date of Call: 06-12-2018 9:45:00
Time of Arrival: 06-12-2018 10:10:00
Rectification Time: 06-12-2018 10:35:00
Time of Departure: 06-12-2018 10:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Chargeable Callout

For Lift(s): 1

For Floor(s): lift car lights

Call Description: lights are out in lift

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Attended call no lights working in lift. On arrival 2 lights working. Electrician arrived on site 5 minutes after me to replace 4 blown downlights

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

courtney ross 0418191478