



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Derby St 56, Kensington
56 Derby St Kensington
Contract No: P3419

Callouts:

Date of Call: 06-11-2018 8:52:00
Time of Arrival: 06-11-2018 11:00:00
Rectification Time: 06-11-2018 11:10:00
Time of Departure: 06-11-2018 11:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 12

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: Bottle cap stuck in door track obstructing door from closing \r\nRemoved and lift return to service

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer

donna