



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Parliament House
100 Spring St East Melbourne
Contract No: P3058

Callouts:

Date of Call: 05-12-2018 7:40:00
Time of Arrival: 05-12-2018 8:25:00
Rectification Time: 05-12-2018 9:45:00
Time of Departure: 05-12-2018 10:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): g

Call Description: OOO ground floor

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Doors out of mesh at ground floor repositioned doors and adjusted lock arm and rollers

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

andrew