

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Caulfield Hospital (S1234)
260 Kooyang Road Caulfield
Contract No: 3565

Callouts: 22498

Date of Call: 06-12-2018 15:45:42 Time of Arrival: 06-12-2018 16:40:00 Rectification Time: 06-12-2018 18:00:00 Time of Departure: 06-12-2018 18:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Opening And Closing

For Lift(s): 1

For Floor(s): ground floor

Call Description: doors opening & closing on the ground floor

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found debris in door track, cleaned tracks, cleaned door locks, cleaned light rays, checked lock clearances, returned to service, tested ok.

Part Required: No Parts Required

Service Technician Report Customer

Nathan Downton Rhonda