



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Wales Corner
227 Collins St Melbourne
Contract No: P3291

Callouts: 22503

Date of Call: 07-12-2018 9:06:00
Time of Arrival: 07-12-2018 9:40:00
Rectification Time: 07-12-2018 10:00:00
Time of Departure: 07-12-2018 10:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 13

Call Description: lift out of order on level 13

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Reset Control System

Work Description: Error code 40 reset and checked operation no fault

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

Brenda 0396232598