



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

55 South Bank Boulevard  
55 South Bank Boulevard South Bank  
Contract No: P3612

**Callouts: 22434**

Date of Call: 29-11-2018 11:22:48  
Time of Arrival: 29-11-2018 11:45:00  
Rectification Time: 29-11-2018 12:05:00  
Time of Departure: 29-11-2018 12:20:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Doors Opening And Closing

**For Lift(s):** 1

**For Floor(s):** 3

**Call Description:** doors are opening & closing on level 3

**Order Number:** CWO0239255

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Door Lock Faulty

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Door lock fault on level 3 cleaned and adjusted ran and tested

**Part Required:** No Parts Required

**Service Technician**

Brad Stellini

**Report Customer**

.