



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

100 Albert Road
100 Albert Road South Melbourne 3205
Contract No: P3614

Callouts:

Date of Call: 06-11-2018 8:16:00
Time of Arrival: 06-11-2018 9:15:00
Rectification Time: 06-11-2018 10:30:00
Time of Departure: 06-11-2018 10:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1,2

For Floor(s):

Call Description: Lifts not allowing access to floors

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift security not working correctly\r\nSwipe cards not unlocking floors\r\nWith security off lifts work correctly\r\nSite contact notified and advised security issue and to log call with them

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer